

Verification of Fire Protection of Shipboard Electric Cables Using Intumescent Coating

Sustainment Panel

24 September 2025

Presented By: David Rice

Hepburn and Sons LLC

NSRP Panel Project

To support the continuing advances in fire protection and affordability, the project will provide initial screening of Specified Technologies Inc. (STI) Marine Cable Coating (MCC)



Problem Statement:

Fires aboard US Navy ships have resulted in damages of more than \$4 billion from 2008 – 2022¹. Layered fire prevention, detection, and response efforts are necessary to reduce the risk.



Problem Analysis


- Major Fires Review provided holistic evaluation of Navy fire prevention and protection systems
 - 12 significant issues addressed
 - 7 strategic recommendations
 - 56 corrective actions and recommendations for lasting impact



(2.B.3.a) Fund the assessment, implementation, and outfitting for both back-fit and forward-fit ships, of improved fire-prevention features and materials, and advanced firefighting equipment. The assessment should include but not be limited to: **(1) the use of intumescent paint (especially in the highest risk areas of ships); ... Improve the timeline of integration and installation of these systems as applicable shipboard and ashore.**

Intumescent Products

- Intumescent process releases gases as part of a chemical reaction triggered by thermal exposure
- Gas production with solid structure combines to form the char layer
- Char layer provides insulation and protection
- Products exist in various forms including sealants, paints, bricks, pillows and more.



Why Cable Coating?

“After flash over, the fire grew quickly in intensity by consuming secondary combustibles and spread to adjoining locations via wireways and outboard frame bays.”


- COMNAVSEA ltr 5830 SER 00/C002 20 May 13, Page 51 para 14.

“Fire extensively damaged cables and cableways spanning the entire length of BONHOMME RICHARD” & “The entire 4 MILLION feet of combat systems and C5I cabling would require replacement.”
SECTION IX.


- RESULTING CONDITION OF BHR. Para 1044.

“The presence of an electrical ground resulted in the erroneous report by some watch standers that this was the cause of the fire. This electrical ground was more likely caused by the fire as it melted electrical cable insulation of live wires.”

- CHAPTER 3. SECTION I. A. 2. BHR Command Investigation



<https://www.navsea.navy.mil/Portals/103/Documents/FOIA-P/ReadingRoom/201411130821.pdf>



Marine Cable Coating

Two critical functions:

- Protect the ship
 - Minimize flame spread
 - Provide additional time for coordinated fire response
- Keep systems operational
 - Prevent cables from shorting causing additional damage
 - Continue to deliver power and communications to critical systems





Helmet-cam view inside BHR published in Command Investigation into the Fire Aboard BHR



Damaged cableways published in Command Investigation into the Fire Aboard BHR

Specified Technologies Inc (STI) Marine Cable Coating (MCC)

- STI provides a suite of fire protection systems
- Intumescent products used throughout product line
- MCC is latex based product that can be applied using standard painting equipment
- Application can be completed by shipyard workers, contractors, or ship forces




William Jones
Marine Manager, North America
(850) 572-1852
wjones@stimarine.com



Testing Overview



NAVSEA Cone Calorimetry Testing (ASTM D6113):

- Evaluate MCC for Heat Release Rate, Smoke Release rate, Mass Loss Rate
- Compare combinations of coatings on cables:
 - Uncoated (baseline)
 - MCC
 - Paint
 - Paint + MCC
 - MCC + Paint



SwRI Modified UL 1666 Testing:

- 154 kW fire exposure
- Vertical orientation of samples representing 2 story run
- Considered worst case scenario for flame spread
- Baseline and coated cables for comparison



FMM Coating Process

- FMM procured approximate 600 feet of cable necessary for test execution
 - LS2SWU-12 per MIL-DTL-24643/33G
- STI delivered MCC to FMM, provided virtual training on recommended equipment configuration and application and had personnel on site during coating process.
- FMM established internal coating instructions, QA procedures, and shipping plans.
- Cables were coated during the week of 16 April.



Cables Delivered

- Test Cables were shipped to both SWRI and NSWCCD during the week of 20 June.



Preparation for Fire Testing at SWRI




STI had personnel at SWRI to inspect and repair coated cables from any damage from shipping during the week before testing. (20 August)



SWRI prepared the Fire Chamber for testing

Fire Testing at SWRI



Bare Cable Setup and Test

Fire Testing at SWRI



Coated Cable Setup and Test



SWRI Results

- As of 19 September, SWRI had not provided their Report and Findings to Hepburn.
- From the pictures received from SWRI, it appears the coating system did not perform as expected.
- Final determination of coating performance and comments will be made once the SWRI information has been received and reviewed. Results will be provided in the project's Final Report.



Testing at NSWCD

- Cone Calorimetry testing at NSWCD has been delayed due to broken equipment. The needed parts have been ordered and awaiting delivery.
- Concerns have been raised regarding the coating application quality from NSWCD personnel.
- Once testing is completed, NSWCD personnel will provide their report to Hepburn. Results will be included in the Final Report.



Status

- Due to delays in cable procurement, cable coating and testing, Hepburn requested and received a NCE until 24 October.
- SWRI completed their fire testing 28 August. Awaiting their report and findings.
- NSWCD is awaiting delivery of test equipment parts to complete Cone Calorimetry testing. Once testing is complete, their report and findings will be sent to Hepburn.
- Hepburn will develop the Final Report, with findings, and provide to NSRP.



Questions?