

# NSRP Panel Project PP 25

[ATI CONTRACT 2018-453-035]

## 15kV MIL-SPEC CABLE DEVELOPMENT FOR U.S. NAVY SHIPS EFFORT

Greg Keyes II  
HII – Ingalls Shipbuilding  
December 12, 2025



DISTRIBUTION STATEMENT A. Approved for public release: distribution unlimited.

# Agenda

- Project Overview
- Project Development
  - Conductor
  - Insulation Material
  - 1/C Designs
  - 3/C Designs
  - Shipyard Feedback
- Current Status of Project
- Schedule
- Questions?


# Project Overview

## BACKGROUND

- Currently no fully qualified MIL-DTL-24643 compliant 15kV class cable exists for use on U.S. Navy ships.
- A low smoke – zero halogen (LSZH) cable was developed and produced for the U.S. Navy Carrier Program Office that is nearly MIL-DTL-24643 compliant.
- Because the cable does not satisfy all of the requirements, a waiver is required from NAVSEA for use on U.S. Navy Ships.

## PROJECT OBJECTIVE & GOALS

- Design, build and test 1C or 3C 400MCM cable rated to 15kV
- Key attributes:
  - In accordance with MIL-DTL-24643D general requirements
  - Circuit integrity using gas flame testing
  - Zero Halogen Materials
  - Waterblocked
  - Flexible to withstand typical installation practices and routings



# Project Team

- **Prime/Lead:**
  - HII – Ingalls Shipbuilding
- **Team Members:**
  - Marmon Aerospace and Defense
  - HII – Newport News
  - GD – Bath Iron Works
  - U.S. Navy: **NAVSEA 05Z33**
- **NSRP Project Manager:**
  - Lydia Szydlo, ATI
- **Program Technical Representative (PTR):**
  - Walt Skalniak (Ashby Co.)



**GENERAL DYNAMICS**  
Bath Iron Works



# Project Development - Conductor

- Most significant contributor to cable flexibility
- Options limited to equipment capabilities
- Waterblocked constructions are limited to 127 components / strands
- Planning to use 127 components consisting of 7 strand lightly waterblocked subcomponents (24 AWG ASTM Class I)
  
- **Rationale:** Much higher flexibility and improved waterblocking than currently used non-waterblocked 127 strand rope construction

# Project Development – Insulation Material


## Primary Insulation Options and Key Performance Characteristics

Material	LSZH	Flexibility	Type of Ash	Fire & CI performance	Voltage Resistance
Polyethylene	Yes	Poor	Conductive	Poor	Excellent
XL EPR	Yes	Medium	Conductive	Fair	Excellent
Silicone	Yes	Flexible	Non-conductive	Very Good	Fair
Silicone/Glass Tape	Yes	Medium	Non-conductive	Outstanding	Poor


- XL EPR and Silicone Rubber are best candidates, but EPR must be enhanced to meet circuit integrity gas flame requirements
- 2 Configurations for mfr and test:
  - **1. XLEPR insulation enhanced with additional layer of silicone-glass tape**
  - **2. Silicone rubber insulation with outer layer of silicone-glass tape**
- **Rationale –**
- Silicone glass tape may enhance the fire performance of the primary EPR insulation while providing better electrical properties than silicone rubber.
- If the EPR/SG sample is not capable of withstanding the flame test, the fallback is a complete silicone rubber solution
- If both configurations fail to meet performance requirements, there is a more complex solution

# Project Development – 1/C Designs

1C SILICONE




1C EPR



Description	Diameter	Min. Bend Permanent	Min. Bend Installation	Weight (Nom. Lbs/ft)
1C Silicone Ins.	1.485	12"	15"	2.52
1C EPR Ins.	1.485	13"	16"	2.47


# Project Development – 3/C Designs

3C SILICONE



- XLPO JACKET
- 24 AWG COPPER STRANDED CONDUCTOR  
889 STRANDS w/ WATER-BLOCKING
- POLYESTER TAPE
- BRAIDED SHIELD
- SEMI-CON FABRIC TAPE
- FILLERS (WATER-BLOCKING)  
(SEE SECTION 3.4.4 OF MIL-DTL-24643)
- CROSS-LAPPED SILICONE GLASS TAPE
- EXTRUDED SILICONE RUBBER INSUL.

3C EPR



- XLPO JACKET
- 24 AWG COPPER STRANDED CONDUCTOR  
889 STRANDS w/ WATER-BLOCKING
- POLYESTER TAPE
- BRAIDED SHIELD
- SEMI-CON FABRIC TAPE
- FILLERS (WATER-BLOCKING)  
(SEE SECTION 3.4.4 OF MIL-DTL-24643)
- CROSS-LAPPED SILICONE GLASS TAPE
- EXTRUDED EPR RUBBER INSUL.

Description	Diameter	Min. Bend Permanent	Min. Bend Installation	Weight (Nom. Lbs/ft)
3C Silicone Ins.	3.000	27"	33"	7.10
3C EPR Ins.	3.00	30"	36"	7.05

# Project Development – Shipyard Feedback

## **Shipyard Cable Pullers:**

- Consensus w/ production personnel across shipyards is that they prefer the 3-conductor designs
- Concerns of possible transit overload when it comes to the 1-conductor designs
- More cable tagging with 1-conductor

## **Design Engineers:**

- Prefers the 1-conductor over the 3-conductor designs
- Transit overload isn't a concern as long as cable pullers pull the cable per design
- The 3-inch diameter on 3-conductor design would be the largest cable diameter used (current largest is ~2.7 inches), and is not feasible due to current spatial constraints
- Recommends a min. bend radius of 24 inches

## **Electrical Hazard Safety Department:**

- About the same risk profile for both 1-conductor and 3-conductor designs
- Mechanical advantages for straights, but at terminal connections would need to use manual pulling for 3-conductor
- Increased risk when pulling multiple 1-conductor cable
- Elevation when pulling cable a factor when it comes to physical strain
- Number of pullers is a risk factor


# Current Status of Project

Marmon A&D is producing samples of the 1-conductor designs of the XL EPR and Silicon Glass Tape for testing


## Test schedule for Finished Cable

Primary wires for testing will have a braided shield applied to better approximate finished cable performance

- Physicals
  - Gas flame (Circuit Integrity) - Gas flame testing is currently planned at SWRI
  - Flame Propagation / Smoke Index
  - Watertightness
  - Voltage withstand (tested against braided shield)
  - Partial Discharge Corona
- 
- In addition, all test parameters in M24643/86 (with voltage adjustment) will be performed
  - Samples for installers will be provided to ensure the cables will be flexible enough to be pulled and routed in typical shipboard installations



# Schedule



# QUESTIONS?

